



January 21, 2022

DMI Drilling Construction  
14211 16th St E.  
Sumner, WA 98390

Attn: Corina Peterson, Project Manager  
E: [Corina@dmidrilling.com](mailto:Corina@dmidrilling.com)  
P: 253-217-0650

Re: Completion Letter for Walls 2, 3, 5 & 6  
Permit BLD20-00011  
Issaquah Middle School No. 6  
1929 NW Talus Drive  
Issaquah, Washington 98027  
Terracon Project No. 81195056

Dear Corina:

As requested, Terracon Consultants, Inc. (Terracon), is providing the completion letter for Walls 2, 3, 5 and 6 (Permit BLD20-00011). Terracon is the designer of record for the Walls 2, 3, 5 and 6 which are permanent soil nails walls and soldier pile and tieback walls with sculpted shotcrete facing. The walls were originally designed as permanent soil nails with sculpted shotcrete facing. However, construction encountered a high groundwater table combined with differing soil conditions, and a portion of Wall 3 was redesigned to be supported with soldier piles and tiebacks with sculpted shotcrete facing. All changes to the original design were resubmitted to the City of Issaquah for approval.

During construction of the Walls, geotechnical special inspection was performed by Associated Earth Sciences, Inc. (AESI) and material special inspection was performed by Krazan & Associates, Inc. (Krazan). Both AESI's and Krazan's reports were provided to Terracon during construction of Walls 2, 3, 5, and 6.

Terracon provided construction administration which consisted of reviewing submittals, responding to requests for information (RFI's), and periodically visiting the site during construction of Walls 2, 3, 5, and 6.

To the best of our knowledge, Walls 2,3, 5, and 6 were constructed in general accordance with the approved plans and specifications.

We appreciate the opportunity to be of service to you on this project. If you have any questions concerning this letter or if we may be of further service, please contact us.



Terracon Consultants, Inc. 21905 – 64<sup>th</sup> Avenue West, Suite 100 Mountlake Terrace, Washington 98043  
P [425] 771 3304 F [425] 771 3549 [terracon.com](http://terracon.com)

Geotechnical



Environmental



Construction Materials



Facilities